DATA SHEET

Liquid Level Switches

Optomax Industrial Series



- Liquid level switches that can detect almost any liquid type;
 oil or water based
- Choice of material; Polysulfone (standard) or Trogamid®
- Choice of threads



Housing/ Mounting







Output Type / Logic







Supply Voltage





Output | Temp



Current





BENEFITS

- High power
- Industrial supply voltage
- Direct load drive design

Housing material^{1, 2} Sensor termination Polysulfone or Trogamid® 20AWG, 250mm PTFE wires, 8mm tinned

TECHNICAL SPECIFICATIONS

or

Supply voltage (Vs)

 $\begin{array}{cc} 4.5V_{DC}\,to\,\,15.4V_{DC}\\ or & 8V_{DC}\,to\,\,30V_{DC} \end{array}$

Supply current (Is)

2.5mA max. (Vs = $15.4V_{DC}$) 7.5mA max. (Vs = $30V_{DC}$)

Output sink and source current (lout)

1A

Operating temperatures

Standard: -25°C to +80°C

Storage temperatures

Extended: -40°C to +125°C Standard: -30°C to +85°C

Extended: -40°C to +125°C

OUTPUT VALUES

Output Voltage³ (Vout): lout = 1A

 $Vs = 4.5 - 15.4 V_{DC}$

Output High Vout = Vs - 1.5V maxOutput Low Vout = 0V + 0.5V max

Output Voltage (Vout): lout = 1A

 $Vs = 8-30V_{DC}$

Output High Vout = Vs - 1.8V maxOutput Low Vout = 0V + 0.7V max



- 1) Above +85°C, Trogamid is suitable for water based liquids. Oil based liquids can cause deformation of the sensing tip and must be tested for compatibility.
- Before use check that the fluid in which you wish to use these devices is compatible either with Polysulfone or Trogamid®.
- 3) Voltages applicable to output value stated.

Apollosense Ltd

henzhen:

Adress: Room 712, Huaneng Building, Shennan Zhong Road, Shenzhen 518031,

China

Tel: (86-755) 83680810 83680820 83680830 83680860 Fax: (86-755) 83680866 Hong Kong:

Adress: Unit 1502, Hollywood Plaza, 610 Nathan Road, Mong Kok, Kln., H.K.


Tel: (852) 2737 0903 Fax: (852) 2737 0938 Email: sales@apollounion.com






HOUSING SPECIFICATIONS


All dimensions shown in mm. Tolerances = ±1mm.




	Housing Series		
	2x0	6x0	7x0
Thread	M12x1x8g with hex nut ¹	1/2" SAE with O-ring ¹	1/4" NPT ²
Pressure ³	7 bar /101 psi maximum		
Tightening Torque	1.5 Nm / 13.26 in-lbs maximum		







Wire	Designation	
Red	Vs	
Green	Output	
Blue	0V	





- Hex nut and O-ring sold separately; email:
- 2) NPT version can be sealed with PTFE tape.
- When correctly sealed.

Apollosense Ltd

Adress: Room 712, Huaneng Building, Shennan Zhong Road, Shenzhen 518031, China

Tel: (86-755) 83680810 83680820 83680830 83680860

Fax: (86-755) 83680866

Hong Kong:

Adress: Unit 1502, Hollywood Plaza, 610 Nathan Road, Mong Kok, Kln., H.K.


Tel: (852) 2737 0903 Fax: (852) 2737 0938 Email: sales@apollounion.com





In order to suit any application, these sensors have been designed with various output circuit configurations. They are identified by the 3-digit code at the end of the part number as shown in Order Information.

N-Type with Flyback Protection Diode N-Type with Flyback Protection Diode High in Air Low in Air Liquid Level Liquid Level Inductive Load Inductive Load Sensor 太 太 O/P O/P N-Type with Internal 10kΩ Pull-Up Resistor N-Type with Internal 10kΩ Pull-Up Resistor High in Air Low in Air Liquid Level Sensor Liquid Level Sensor N-Type High in Air N-Type Low in Air +Vs Liquid Level Liquid Level External Load External Load Sensor Sensor O/P O/P P-Type High in Air P-Type Low in Air Liquid Level Sensor Liquid Level Sensor O/P O/P xternal Load xternal Load 0 0 N&P-Type Push Pull High in Air N&P-Type Push Pull Low in Air +Vs +Vs Liquid Level Liquid Level External Load 1 External Load 1 O/P External Load 2 External Load 2




The minimum load impedance should not exceed Vs/max output current.

Note: Shorting the output to Vs or 0V will result in irreparable damage to the sensor.





Generate your specific part number using the convention shown below. Use only those letters and numbers that correspond to the sensor and output options you require — omit those you do not.





Do not exceed maximum ratings and ensure sensor(s) are operated in accordance with their requirements.

Carefully follow all wiring instructions. Incorrect wiring can cause permanent damage to the device.

Apollosense Ltd recommend using alcohol based cleaning agents. Do NOT use chlorinated solvents such as trichloroethane as these are likely to attack the sensor material.

Failure to comply with these instructions may result in product damage.

INFORMATION

As customer applications are outside of Apollosense Ltd.'s control, the information provided is given without legal responsibility. Customers should test under their own conditions to ensure that the equipment is suitable for their intended application. Before use, check that the fluid in which you wish to use these devices is compatible with Polysulfone or Trogamid®.

General Note: Apollosense Ltd. reserves the right to make changes to product specifications without notice or liability. All information is subject to Apollosense Ltd.'s own data and considered accurate at time of going to print.

Apollosense Ltd

Shenzhen:

Adress: Room 712, Huaneng Building, Shennan Zhong Road, Shenzhen 518031,

China

Tel: (86-755) 83680810 83680820 83680830 83680860 Fax: (86-755) 83680866

Hong Kong:

Adress: Unit 1502, Hollywood Plaza, 610 Nathan Road, Mong Kok, Kln., H.K.

Tel: (852) 2737 0903 Fax: (852) 2737 0938 Email: sales@apollounion.com